

**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE**

LISTING No. 7165-0061:110

Page 1 of 2

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Chemetron Fire Systems, 4801 Southwick Drive, Matteson, IL. 60443
Contact: Rick Misiaveg (708) 748-1503 FAX (708) 748-2847

DESIGN: Model MICRO-640I and MICRO-640IE fire alarm control units. Local, auxiliary, remote station (PPU), proprietary (PPU), central station (PPU), automatic, manual, waterflow and sprinkler supervisory services. Refer to listee's data sheet for detailed product description and operational considerations. System components:

MICRO-640-CPU, 640-CPUE	CPU Board
MICRO-NCA	Network Communication Annunciator
MICRO-ABF-1B, -1DB, -2B, -2DB, -4B	Annunciator Flush Boxes
MICRO-ABS-1TB, -1B, -2B, -4B	Annunciator Surface Boxes
MICRO-AKS-1B	Annunciator Key Switch
LEM-320	Loop Expander Module
KDM-2	Keyboard Display Module
TM-4	Transmitter Module
CAB-4 Series	Enclosure
TR-A4, -B4, -C4, -D4	Trim Ring
DP-DISP	Display Dress Panel
DP-1B	Blank Panel
BMP-1	Blank Module
XPDP, DPDW-1B, DPSW-1B, VP-2B	Dress Panels
CHS-4MB, -M2, -4L, -4N	Chassis
NFS-LBB, BB-25, BB-17	Battery Box
BP-4	Battery Panel
STS-1	Security Tamper Switch
UDACT	Universal DACT
UZC-256	Universal Zone Coder
RPT-W, RPT-485W, RPT-485WF	Repeater Wire
RPT-F	Repeater Fiber
SCS-8	Smoke Control Station
SCE-8	Smoke Control Expander
SCS-8L	Smoke Control Lamp Driver Station
SCE-8L	Smoke Control Expander Lamp
ARM-4	Auxiliary Relay Module
APS-6R/APS-6RE	Auxiliary Power supply
ACPS-2406	Addressable Power Supply
CHG-120	Battery Charger
FCPS-24	Field Charger Power Supply
DCM-4RK	Dual Channel Module
CRM-4RK	Control Relay Module
CRE-4	Control Relay Expander
ICM-4RK	Indicating Control Expander
ICE-4	Indicating Circuit Expander
ISO-X	Isolator Module
XP5-M, XP5-C	Transponder
XPIQ	Transponder Quad Intelligent Audio
XP6-C,	Supervised Control Module
XP6-R	Six Relay Control Module
XP6-MA	Six Zone Interface Module
XP10-M	Ten Input Monitor Module
XPC-8	Transponder Control Module
XPM-8, XPM-8L	Transponder Monitor Modules
XPP-1	Transponder Processor

XPR-8
VS4095
CRT-2
NBG-12LX
NBG-12LRA
FZM-1
REL-2.2K

Transponder Relay Module
Keltron Remote Printer
Display Terminal
Addressable Manual Pull Station
Agent Release Abort Station
Interface Module
Releasing Supervision Kit

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 2002 Edition. Refer to listee's Installation Instructions Manual for details.

This control unit meets the requirements of UL-864, 8th Edition Standard.

NOTE: For **Fire Alarm Verification** feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

XLF: 7165-0028:214

12-06-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 4, 2007**

*Listing Expires **June 30, 2008***

Authorized By: **MIKE TANAKA, Senior Deputy State Fire Marshal**
Program Manager